

NOTICE

TO: All plan holders

DATE: May 27, 2020

FROM: Cory Christiansen, PE
Project Manager
Water Works Engineers
1955 W. Grove Parkway, Suite 101
Pleasant Grove, Utah 84062
(801) 556-3725

SUBJECT: Addendum No. 1 to the Contract Documents for the STRUVITE CONTROL SYSTEM PROCUREMENT for the PROVO WATRR CENTER PHASE 1 2020 CONSTRUCTION

Transmitted herewith is ADDENDUM No. 1 to the contract documents for the above-mentioned project.

Notes and Clarifications:

1. Progressive cavity pumps are to be used for the struvite control feed pumps per 46 75 50 2.2C1b. If the Struvite Control System Supplier (SCSS) believes there is a better pump selection for their system, it can be used as long as this is identified in the proposal documents.
2. Progressive cavity pumps are to be used for the sludge discharge pumps per 46 75 50 2.2C3c. If the Struvite Control System Supplier (SCSS) believes there is a better pump selection for their system, it can be used as long as this is identified in the proposal documents.
3. The height of the ceiling in the secondary digester building is 8ft 3in from finished floor to ceiling.
4. Please include the 100% performance bond price in the Additional Adder line item provided in the table Lump Sum Proposal for Proposal Item 1: Struvite Control System in Article 2.01A1 of the Proposal Form.
5. The 5% Bid Bond shall be included in the price of the base Proposal Item 1-1 in the Lump Sum Proposal for Proposal Item 1: Struvite Control System table.

All bids submitted without the signed acknowledgment of this Addendum will be rejected.

ADDENDUM No. 1

PART 1 GENERAL

1.1 DOCUMENT INCLUDES

- A. Changes to the Bid Documents.

1.2 CONSTRUCTION CONTRACT

- A. FINE SCREEN SYSTEM PROCUREMENT for the PROVO WATR CENTER PHASE 1 2020 CONSTRUCTION
- B. Project No. 19-002
- C. Date: May 27, 2020

PART 2 CHANGES

2.1 CHANGES TO PRIOR ADDENDA

- A. NONE

2.2 CHANGES TO BIDDING REQUIREMENTS

- A. NONE

2.3 CHANGES TO AGREEMENT AND OTHER CONTRACT FORMS

- A. PROPOSAL FORM FOR PROCUREMENT CONTRACT Article 2.01 Paragraph A 2 b

Replace:

“30-Days”

With:

“25-Days”

2.4 CHANGES TO CONDITIONS OF THE CONTRACT

- A. NONE

2.5 CHANGES TO SPECIFICATIONS

- A. NONE

PART 3 ACKNOWLEDGEMENT

3.1 Acknowledgement of receipt of this addendum is made in Paragraph 5.02 in Article 5 of the PROPOSAL FORM FOR PROCUREMENT CONTRACT.

3.2 All bids submitted without the signed acknowledgment of this Addendum will be rejected.

END OF ADDENDUM